

MOVEMENT TO THE FULL DIGITAL SUBSTATION FOR PRIMARY DISTRIBUTION

Simon RICHARDS
Alstom Grid - UK
simon.richards@alstom.com

Denis CHATREFOU
Alstom Grid - France
denis.chatrefou@alstom.com

Andreas PROCOPIOU
Alstom Grid - France
andreas.procopiou@alstom.com

ABSTRACT

Digital devices such as numerical protection relays and digital systems such as substation control are prevalent as the technology of choice in substations today. This article looks at other substation areas into which digital technology can permeate, such that progressively, substations can become fully digital in their implementation.

INTRODUCTION

Firstly, one might ask “what is a digital substation?”, and this will yield a variety of possible replies, as there is no standard definition. Clearly as most substations today are switching and routing AC power at high/extra high voltage, it is not the primary flow which is digital. This means that we are talking about the secondary systems, and all the protection, control, measurement, condition monitoring, recording and supervisory systems associated with that primary “process”.

In general terms, a full digital substation is one in which as much as possible of the data related to the primary process is digitised immediately, at the point where it is measured. Thereafter, the exchange of that measured data between devices which may need to subscribe to it is via Ethernet, as opposed to the many kilometres of copper hardwiring which may exist in a conventional substation.

Digital substations imply a solution and architecture in which the substation’s functionality is predominantly now achieved in the software, with lesser reliance on hardware implementations such as hardwiring.

DRIVERS TOWARDS DIGITAL SUBSTATIONS

Some of the areas in which digital technology brings real benefits are now highlighted:

Increased reliability and availability

The extensive self-diagnosis capability of digital devices ensures maximised up-time of the substation. Any degradation in the performance of an asset is pinpointed in real-time. Inherent redundancy in the system may be employed to self-heal the operation, which permits troubleshooting without the need for any primary system outage.

Optimised operation of assets

The intelligence within digital substation schemes allows close monitoring of the loadflow capacity of plant

equipment, compared to its design ratings.

Improved safety

The removal of wired cross-site current transformer circuits reduces the risk of lethal injury due to inadvertent opening of the circuit by personnel. The avoidance of oil in instrument transformers reduces explosion risks too.

Reduced maintenance costs

The digital substation closely monitors all substation assets. Intelligent systems analyse the data and provide recommendations on maintenance and repair actions to conduct. This allows a shift to predictive or reliability-centred maintenance, avoiding unplanned outages and emergency repair costs. It is in this regard that ongoing operational cost savings may be made, such that the lifetime total cost of ownership of the substation will be reduced.

Easier renovation and extension of existing substations

Interoperable solutions and the use of fibre optics instead of copper wires reduce the duration and cost of on-site work for the refurbishment of secondary equipment. Prudent design of the substation plans ahead for the mid-life refurbishment of secondary schemes, when often the primary equipment is left as-is, given that decades of years of serviceable life may still remain. This permits the refurbishment activity to take place with the absolute minimum of primary system outage.

Improved communications capabilities

Data exchange between intelligent devices, intra and inter-substation, is optimised through Ethernet communications. Smart local and wide area control units (WACU) can allow data exchange between voltage levels in substations, and between substations. Direct inter-substation communication without the need to transit via a control centre reduces the response times, for fast, real-time applications.

IEC 61850: THE TECHNOLOGY ENABLER

IEC 61850 is the international standard for Ethernet-based communication in substations. IEC 61850 allows for the full digitising of the signals in a substation and is necessary for the large amount of data to be managed and communicated for the real-time management of a smarter, modern power grid. IEC 61850 is designed for interoperability and longevity, in order to be independent from any supplier.




Fig. 1 – Architecture levels in a digital substation

ARCHITECTURE OF DIGITAL SUBSTATIONS

The process level

A digital substation is based on a communicating architecture, whereby real-time operational measurements are polled from the primary system. This data is obtained using sensors, embedded within the primary system, which is termed as the electrical process. It is communicated to devices which must act on those measurements by means of a “process bus”. Most important is that smart devices and systems within the substation can immediately process this operational data. By subscribing as clients to this data flow over an Ethernet process bus, the information from the “eyes and ears” of the power system is distributed and communicated much more efficiently to the bay level than in conventional hardwired schemes.

The process bus is also the link by which the primary equipment information from out in the yard travels back to the substation control house – it links the field back to the substation. In a fully digital architecture, control commands (switchgear operator commands, protection trips) also are

routed to the primary devices via the process bus, in the opposite direction.

The protection and control level

Between the process bus and the station bus are devices historically identified as the “secondary equipment”. In the digital substation, these devices are IEDs (intelligent electronic devices), interacting with the field via the process bus, and with other peer devices in the bay, to other bays, and the digital control system via the station bus.

The station control area

The digital substation station bus is much more than a traditional SCADA bus, as it permits multiple clients to exchange data, supports peer-to-peer device communication, and links to gateways for inter-substation wide-area communication. GOOSE is more often than not used as high-speed exchange of binary status information/commands.

In addition to the need for distributed intelligence between IEDs at the station level, there is the need to distribute the information to local or remotely-stationed control operators to visualise the operational status of the substation.

DIGITAL INSTRUMENT TRANSFORMERS

The root of many of the limitations of conventional instrument transformers is the reliance upon an iron core. The core is a source of inaccuracy, due to the need to magnetise it, but not to overflux it. In the case of conventional CTs, achieving the low-level accuracy and dynamic range to satisfy both measurement and protection duties is a challenge. Instead of an iron core, the translation from primary to secondary measurement may use optical, Rogowski or capacitive technology, with the optimum choice for AIS (Air-Insulated Substation) and GIS (Gas-Insulated Substation) driven by the respective digital device size, which in turn permits size optimisation of the switchgear. Some examples of the principles are as follows, considering just the CT function here for brevity:

- Optical sensors (AIS) use the Faraday effect, whereby a fibre optic loop sensor carrying a polarised light beam encircles the power conductor. This light will experience an angular deflection due to the magnetic field, generated by the primary current flow.
- Rogowski sensors (GIS) dispense with the conventional CT core and instead implement windings as tracks on a multi-layer printed circuit board. Four quadrants of the board are clamped together to form a toroid around the primary conductor. The sensor output becomes a low-level voltage measurement, which can be accurately correlated to the primary current.



Fig. 2 - Example optical CT showing freedom to mount in different orientations, such as horizontally

ANALOGUE SIGNAL CONVERSION, MERGING AND SWITCHGEAR CONTROL

Primary converters associated with each CT and VT convert analogue signals from the primary equipment into digital signals. The primary converters interface with merging units to perform all the digital data processing necessary to produce a precise output data stream of sampled values according to the IEC 61850-9-2 standard.

For retrofitting, or where the client has a preference to retain traditional instrument transformers, analogue merging units are available, digitising the CT and VT outputs at any

convenient kiosk out in the yard.

Digital controllers (SCU - switch control units) are the fast, real-time interface to switchgear, mounted close to the plant which they command. They replace hardwiring of inputs/outputs by an Ethernet interface to the yard.



Fig. 3 - Example merging unit

NUMERICAL PROTECTION RELAYS

In a fully-digital architecture, protection relays receive currents and voltages as IEC 61850-9-2 sampled values, and issue trip or alarm signals using IEC 61850-8-1 GOOSE.

The authors' company's IEDs extend their supervision facilities to include comprehensive addressing and plausibility checking of the incoming sampled values from the process bus. This addresses the fact that the traditional task of current and voltage sampling is now external to the device, and is connected via Ethernet. This ensures maximum security, dependability and speed of the protection scheme.



Fig. 4 - Example process bus protection relay

DIGITAL CONTROL SYSTEM (DCS)

The DCS is the intelligence which binds together the digital substation. It is central to the flow, management and presentation of all components in the digital substation. In the authors' company, specific focus has been paid to the way that operational and plant condition monitoring data has been networked, for the first time, within what would have traditionally been exclusively a protection and control system. This avoids the need to overlay multiple Ethernet

networks, as the system is deployed as a generic whole. In addition, attention has been paid to how data can be presented as simple dashboards, such that operational staff can clearly see what is happening on the network, easing subsequent decision-making on actions to take.

All digital substation architectures can be set up as an IEC 62439 standards-compliant self-healing ring (HSR protocol) or dual-homing star (PRP protocol); both of which are “bumpless” redundant. This means that data is exchanged between devices via two diverse paths, and should one of these paths fail, data is instantly available hot from the other, with zero delay. Fibre optic networks link all the system’s components, together and with the operator interface (HMI), through a full range of Ethernet switches.

Wide area control units (WACU) offer the possibility to exchange IEC 61850 GOOSE data between voltage levels within a substation and also between neighbouring substations.



Fig. 5 - Digital Control Systems: the marriage of state-of-the-art software and intelligent electronic devices

Cyber security

Cyber security provides protection against unauthorised access to equipment and unauthorised transfer, modification or destruction of data – whether deliberate or accidental. Security procedures, controls, firewalls and role-based access are all examples of such measures.

On-line condition monitoring and asset management

Condition monitoring functions are mainly delivered for power transformers, circuit breakers, disconnectors and gas insulated switchgear. Physical parameters are continuously monitored and real-time measurements are combined and compared to models in order to generate specific recommendations regarding operation and maintenance, as well as alarms when necessary. The new architecture enables utility teams to have an overview of the condition of all substations in real time, and take appropriate and strategic asset management decisions.

EXAMPLE COMMERCIAL PROJECTS

Energinet, Denmark – Digital Current Measurement and Protection

One current application is on Energinet’s transmission system, in a differential protection application. The protected circuits are hybrid lines, consisting of 400kV lines, and cabled portions laid sub-sea. The cables are over 20km in length, and the operational demands are such that autoreclosing is required for faults on the overhead lines, but not for faults within the underground cable sections. The differential protection is thus used for fast and precise detection of faults within the cables. The undersea cables run from stations on the Jutland mainland, on to Funen island and then onwards to Zealand.

The equipment supply includes 72 optical CT units, 24 merging units and 24 line differential relays which subscribe to the sampled values in a process bus protection scheme. The principal reason for selecting to use non-conventional instrument transformers was due to their low mass and slimline construction. In the Energinet substations, the optical CTs are mounted on the same support structures as the cable bushings themselves. A single structure and foundation per phase carries the larger mass of the cable, plus the optical CT support on a cantilever frame.

FSK, Russia – Conventional Analogue Instrument Transformers Interfacing to Full Digital Protection and Control

In the 110kV and 220kV substation contracts for Nadezhda in Russia, the primary GIS equipment is supplied by a 3rd party vendor, equipped with conventional instrument transformers (wound CTs and VTs). This analogue data is digitised at source using analogue merging units, and connected cross-site to relays and bay controllers by an IEC 61850-9-2 process bus.

A full range of transmission relays protect the substations, interfacing with the digital control system. The architecture of the substation incorporates PRP redundancy. Trip and operational control of switchgear is secured using SCU switchgear control units, completing the full digital acquisition and command chain.

CONCLUSION

These two contract examples demonstrate the maturity of the technology, the faith placed in the technology by two important customers, and hence the readiness for other customers to adopt. The authors believe that we are in the ramp-up phase of digital substation technology, and that the market will continue to grow, worldwide.